



OK

# Storage Temperature Report

## Additional Information

Data Logger for temperature recording in: Storage Room 2\_Floor 1

- 1) Create this PDF report MONTHLY according to guideline SE\_404634
- 2) Send PDF report MONTHLY to ambient\_storage@xyz.com
- 3) The Data Logger must be put back in its original fixture after having created the PDF report (according to guideline SE\_404634)

## Device Configuration

Type:	Libero Ti1 V1.28	Inspection Range:	Last Transit to Arrived
Logger ID:	10042390	Current State:	Switched Off
Log Interval / Duration:	5 m / 55.6 d	Remaining Battery:	0 d
Log Mode:	Loop	Logger Start:	12.Feb.2011 09:45:20
Report Time Base:	GMT +01:00	Checksum:	PA01 / 1.669.775.683
Configured by:	S184, EC50/ameier, 01.Feb.2011 16:41:30		

Alarm Conditions	Total Time	Status
Upper Threshold: 22.0 °C	Time above Threshold: 0 s	OK
Lower Threshold: 10.0 °C	Time below Threshold: 0 s	OK
Alarm Delay: 5 m		

## Logging Results

Highest Temperature:	19.7 °C; 03.Apr.2012 16:15:20	Transit Start at:	03.Apr.2012 09:21:06
Lowest Temperature:	16.1 °C; 06.Apr.2012 06:30:20	Arrived at:	06.Apr.2012 09:45:04
Average Temperature:	18.1 °C	Alarm at:	none
MKT	18.2 °C	File created:	20.Apr.2012 15:16:14

